

CONSTRUCTION OF SMALL POWER PLANTS AT OIL AND GAS FIELDS



Dragan Vignjevic


064 888 24 36

dragan.vignjevic@nis.eu

Engineer for thermalpower

Block Energy

The process of preparing crude oil for transport




Gas composition

Oil field	CH ₄	C ₂ H ₆	C ₃ H ₈	iC ₄ H ₁₀	nC ₄ H ₁₀	iC ₅ H ₁₂	nC ₅ H ₁₂	C ₆ H ₁₄₊	N ₂	CO ₂
Sirakovo	78,43	11,78	4,86	0,86	1,67	0,49	0,64	0,97	0,12	0,18
Velebit (dissolved gas)	81,55	4,41	0,47	0,07	0,04	0,01		0,04	4,01	9,4
Velebit (permeate gas)	59,81	1,05	0,04	0	0	0	0	0	5,71	33,39
Kikinda	85,19	5,41	3,58	1,22	1,71	0,53	0,64	0,25	1,44	0,03
Turija	76,42	4,54	5,33	1,37	2,77	0,95	0,96	1,19	0,42	6,05
Boka	83,86	2,88	1,79	0,37	0,87	0,27	0,42	0,73	6,56	2,25
Bradarac	70,95	14,68	7,84	0,94	1,55	0,37	0,38	0,2	0,24	2,85
Majdan X	36,88	3,55	1,96	0,34	0,67	0,18	0,20	0,32	9,57	46,32
Srbobran	49,60	1,14	0,37	0,08	0,15			0,07	10,01	38,58


Constructed small power plants

	Electric power	Thermal power	Gas consumption	Electrical efficiency	Engine manufacturer	Put in operation
	kW	kW	Nm ³ /h	%		
Sirakovo	850	904	172	39,9	Caterpilar	August 2013
Sirakovo 2/1	1.000		197	43,1	Caterpilar	June 2015
Sirakovo 2/2	1.000		197	43,1	Caterpilar	June 2015
Velebit 1	995	1040	256	42,6	Caterpilar	December 2013
Velebit 2	995	1040	256	42,6	Caterpilar	December 2013
Velebit 3	1.000		394	41,2	Caterpilar	January 2015
Velebit 4	1.000		394	41,2	Caterpilar	January 2015
Kikinda	995	1100	241	41,3	Jenbacher	November 2013
Turija	995	1118	196	40,6	Caterpilar	December 2014
Boka	330	370	77	41,4	Caterpilar	September 2014
Bradarac	300	345	57	40,9	Caterpilar	December 2014
Majdan X	2400		1185	39,5	R-Schmitt	August 2016
Srbobran 1	995		450	41,5	Caterpilar	August 2014
Srbobran 2	995		450	41,5	Caterpilar	August 2014
Sum	13.860	5.917	4.522			

Locations of small power plants




Gas consumption and electricity generation



Applied technology


Gas dryer



Gas 2333 kW

Container of small power plant

- IC engine coupled with generator
- Equipment for heat delivery
- Auxiliary equipment



1000
kWb

960 kWn

40 kW (4%
own
consumption)

1040 kW Hot water 90/70° C

Container of electric power unit


- Transformer 0,4 kV / 20 kV
- Switch gear



940 kWn


20 kW (2%
losses)

P&ID of the cogeneration plant




TEDOM NÁZEV Schéma Quanto D 1200
SAS-SAN 9/12
Sokne 10332 SD 12.40

Energy balance of small power plant



Parameter	Unit	100	75	50
Rating	%	100	75	50
Electric power ISO 5828-1	kW 8%	995	746	498
Thermal power engine circuit	kW 8%	517	401	291
Thermal power technological circuit / low temp	kW 8%	82	55	33
Thermal power exhaust gases at 120 °C	kW 8%	523	430	322
Radiation losses	kW 8%	41/27	38/23	33/20
Thermal power	kW 8%	1040	831	613
Temperature of exhaust gases	°C	437	461	486
Mass flow of exhaust gases	kg/h	5.403	4.114	2.860
Mass flow of air for combustion	kg/h	5.173	3.937	2.735
Fuel power	kW 5%	2.333	1.806	1.275
Electrical / thermal efficiency	%	42,6/4	41,3/4	39,0/4
		4,6	6,0	8,1
Overall efficiency	%	87,2	87,3	87,1


P&ID scheme of gas dryer






Challenges during construction and exploitation of small power plants

- High content of inert gases (CO_2 , and N_2), such as gas from the Srbobran gas field and gas from the oil field Majdan.
- Increased content of heavy hydrocarbons in gas.
- Reduction of emissions of harmful gases into the atmosphere (CO , NO_x).
- Increased H_2S content, as a consequence H_2S extraction facilities is installed.
- Interruption of gas supply - example small power plant (SMP) Bradarac and installation of gas buffer.
- Fluctuations in heat demand - example ME Bradarac and construction of heat accumulator.
- In order to secure continuous operation of electricity consumers at the oil field Velebit in an event of a power supply interruption caused by ED grid failure isolated operation of SMP Velebit 1 and 2 is established. Isolated operation of SMP is secured by installation of load banks. In such a way losses in oil production due to power supply failure are avoided or reduced to minimum.
- Connection points on the ED grid - installation of long cable connections (SMP Sirakovo 2 - 5 km, SMP Srbobran - 4 km).


Increased H₂S content and H₂S extraction facilities



Interruption of gas supply - installation of gas buffer as tech. solution




Isolated operation and installation of load banks on Plant Velebit 1 & 2



Economic evaluation of projects

Electric power	1000	kWe
Net/gross power	0,94	
Electrical efficiency	42,6	%
Thermal power	1.040	kWth
Thermal efficiency	44,6	%
LHV	40	MJ/Sm ³
Gas consumption	210	Sm ³ /h
Annual working hours	8.000	h/year
Investment cost	1.350.000	Euro
Price of electricity	71,83 – 78,54	Euro/MWh
Price of heat	0,00	Euro/kWh
Price of fuel	0,00	Euro/Sm ³
Maintenance cost	9,00	Euro/h
General overhaul cost	250.000	Euro
Taxes	20	%
Discount rate	14	%

Investment cost	1.350.000	€
Project time period	15	years
NPV	873.544	€
PI	1,67	-
DPP	5,22	years
IRR	30%	%



THANK YOU FOR YOUR ATTENTION

